

## Source Inspection Report

COMPANY: Lear Seating Corporation  
1401 165<sup>th</sup> Street  
Hammond, Indiana 46320  
(219) 852-0014

<u>*Violation(s) Observed (Y/N)?</u>	
<b>State</b>	No
<b>Local</b>	No

SOURCE ID NUMBER: N/A                      INSPECTION DATE: July 14, 2016  
SOURCE CLASSIFICATION: Local                      LEVEL: 2  
OPERATION PERMIT TYPE: Local                      TYPE: Annual  
OPERATION PERMIT NO(s): 03748  
ISSUE DATE: April 19, 2016                      INSPECTOR: Michael Zabrecky  
PERMIT REVISION DATE: N/A  
REPORT WRITTEN BY: Michael Zabrecky

FACILITIES INSPECTED: Onan Diesel Generator

PERSON(s) INTERVIEWED: Willis Chen, Engineering Manager

INSPECTION OBJECTIVE(s):

To perform an unannounced inspection to evaluate Lear Seating Corporation's compliance with applicable air pollution regulations specified in their local operation permit.

SUMMARY OF INSPECTION:

On July 14, 2016 an Annual Inspection was conducted at Lear Seating Corporation. This facility holds one (1) operation permit for one (1) Onan Diesel Generator.

The generator was not in operation.

No violations or modifications observed.

## Source Inspection Report

Lear Seating Corporation - 7/14/16

Plant ID: N/A

### ENTRY INTERVIEW:

Upon entry, I met with Willis Chen, the Engineering Manager for Lear Seating Corporation. I informed him that this is an Annual Inspection and that I wanted to inspect the locally permitted item.

### INSPECTION OBSERVATION(s):

1. Process Equipment: Onan Diesel Generator:
2. Process Description:  
A 3.413 MMBtu/hr generator utilizing No. 2 Diesel will be used for emergency purposes only.
3. Pollutants Emitted:  
Particulate matter (PM), sulfur dioxide (SOx), nitrogen oxide (NOx), volatile organic compounds (VOC), and carbon monoxide (CO)
4. Control Equipment:  
There is no control equipment.
5. Applicable Rules:  
Provisions of 326 IAC Article 2 and Hammond Ordinances #7102 and #3522 (as Amended)
6. Emission Limitations:

PM	= 0.129 lbs/hr	= 0.566 Tons Per Year (TPY)
SOx	= 0.464 lbs/hr	= 2.032 TPY
NOx	= 1.292 lbs/hr	= 5.659 TPY
VOC	= 0.013 lbs/hr	= 0.057 TPY
CO	= 0.323 lbs/hr	= 1.415 TPY
7. Other Permit Requirements:  
See the General Operation Conditions for 2016.
8. Observations:  
The generator was not in operation. No modifications were observed.
9. Records Review:  
No record review is required.
10. Compliance Status:  
No violations observed during the inspection.

### CONCLUSION(s)/RECOMMENDATION(s):

The generator was inspected. No violations, visible emissions, or new sources of air emissions were observed.